

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-21-09-17-04

**Product:** MMF floor covering „Kronostep“, thickness: 4 mm  
Structures: Peetah (PT), Hickory Scrape (HS), Flanders Oak (FN), Stone Oak (SO)

**Producer:** Kronoflooring Sp. z o.o., ul. Przemysłowa 10, 38-200 Jasło, Poland

**Order:** Testing and classification of selected properties  
according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling)

**Test report:** 2718587, 2719182, 2719250, 2118065/2021/F

**Test results:**

Property	Declaration according to EN 14041:2004+AC:2005 +AC:2006
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, classification according to EN 13501-1	Reaction to fire class B <sub>fl</sub> -s1
Anti-sliding properties according to EN 13893	Class DS
Thermal resistance according to EN 12667	0,008 (m <sup>2</sup> K)/W

Dresden, 17/09/2021

Head of laboratory



Engineer in charge